



NOTES:

- UNIT TO BE DOUBLE WALL CONSTRUCTED WITH INWARD TURNED FLANGES, BOLTED TOGETHER AND CAULKED WITH URETHANE CAULKING
- UNIT EXTERIOR TO BE 16 GA. GALVANNEALED STEEL PAINTED WHITE EPOXY
- UNIT INTERIOR TO BE 16 GA. STAINLESS STEEL WITH A #4 FINISH
- ELECTRICAL WIRING TO CONFORM TO LATEST NEC STANDARDS
- SINGLE SOURCE 115V / 60HZ / 15A POWER SUPPLY REQUIRED
- UNIT SHIPPED IN ONE PIECE FOR EASE OF INSTALLATION
- DOORS TO BE ELECTRICALLY INTERLOCKED
- ALL ACCESS PANELS TO HAVE CLOSED CELL NEOPRENE GASKETING AND ARE TO BE FASTENED IN PLACE WITH STAINLESS STEEL FASTENERS
- UNIT TO BE SUPPLIED WITH 1 1/2" X 1 1/2" X 16 GA. STAINLESS STEEL ANGLE IF REQUIRED (TO BE FIELD INSTALLED)
- ROUGH OPENING TO BE 1/2" LARGER THAN OUTSIDE DIMENSION OF UNIT

REVISIONS			
REV	DESCRIPTION	DATE	APPROVED

- ① 1 EA. 28" X 80" FIRE RATED DOOR TO BE 16 GA. STAINLESS STEEL, 1 1/2 HOUR RATING, UL "B" LABELED, SUPPLIED WITH CHROME PLATED KNOB SET, BUTT HINGES, 10 X 10 WIRE GLASS WINDOW AND SELF CLOSER WITH STAINLESS STEEL COVER
- ② 1 EA. 36" X 80" FIRE RATED ROLL-UP DOOR TO BE STAINLESS STEEL WITH MOTOR
- ③ 1 EA. 10 X 10 WIRE GLASS VIEW WINDOW ON REAR OF UNIT
- ④ 1 EA. 24 X 24 X 3 1/2" THK. ALUMINUM FRAMED HEPA FILTER 99.99% EFFICIENT ON 0.3 MICRON SIZE PARTICLES, GEL SEALED, REPLACABLE FROM BELOW
- ⑤ 8" DIA. SUPPLY AIR DUCT COLLAR
- ⑥ 8" DIA. EXHAUST AIR DUCT COLLAR
- ⑦ 1 EA. 2" PVC SPRINKLER SLEEVE
- ⑧ 1 EA. FLUSH MOUNTED FLUORESCENT LIGHT FIXTURE, 2-TUBE 20W
- ⑨ 2 EA. LIGHT SWITCHES, ONE ON EACH SIDE
- ⑩ 1 EA. UP-DOWN PUSH BUTTON FOR MOTORIZED ROLL UP DOOR
- ⑪ 1 EA. INTERNAL PERFORATED STAINLESS STEEL SHELF ON STAINLESS STEEL TUBING, 45" HIGH, ADJUSTABLE TO 50" AND 55" HIGH
- ⑫ EMERGENCY STOP BUTTON (MUSHROOM HEAD TYPE)
- ⑬ ELECTRONIC CONTROLS ENCLOSURE

(1) UNIT REQUIRED, AS SHOWN

DRAWN FOR		HALCO PRODUCTS COMPANY 100 NORTH GORDON ST, ELK GROVE, ILLINOIS 60007			
		TITLE PASS THRU - PT3080-64/FD/EI/SS			
DRAWN BY	LVB	SIZE	JOB NO. 9071	DWG NO. 159845BC	REV
APPROVED BY		SCALE	3/8" = 1' - 0"	DATE 5-27-98	SHEET